



1	AXIALLY LOCATING BEARING 6038/C3+NU1038/C3
2	INSULATED SHIELD AXIALLY FREE BEARING NU1038/C3
3	TERMINAL BOX FOR ACCESSORIES BLIND FLANGE
4	GREASING NIPPLE DE AND NDE
5	SPM NIPPLE DE AND NDE
6	WATER INLET FLOW 29.9 m ³ /h 38°C DN50 DIN 2633 PN16
7	WATER OUTLET DN50 DIN 2633 PN16
8	PT100, BEARING
9	SEPARATE FAN
10	SPACE HEATER
11	TERMINAL BOX FOR SPACE HEATER BLIND FLANGE
12	WATER LEAKAGE DETECTOR
13	RATING PLATE
14	MAIN TERMINAL BOX 1 ROXTEC
15	MAIN TERMINAL BOX 2 ROXTEC

Customer Reference		Our Reference	Protection/Coiling
Sekwang:		6837HF200	IP55 1C86W
Additional Information			
Prepared	2009-07-21 R. SANTI	Separate part list with separate No.	<input type="checkbox"/>
Reviewed	2009-07-21 TA	Responsible Department	ATAP/PIE2
Approved	2009-07-21 MH	Original Dwg	<input type="checkbox"/>
Distribution	14	Functional Code	AH
Order No.		Weight	9100 kg
Type	AMI 560L6L BAFTMH	Mounting	IM 1001
Document No.	3AFP 9925667	Revision	E 1/1

E	DIRECTION OF ROTATION CHANGED	2010-07-26	MAT4	TA	JR
D	TOP VIEW AND CENTER OF GRAVITY CORRECTED, DIMENSIONS UPDATED	2010-02-23	MAT4	HL	TL
C	MIB, AIB AND WATER CONNECTION MOVED TO OTHER SIDE	2010-02-19	MAT4	HL	TL
B	TOP VIEW ADDED	2009-11-23	RISA	LT	ES
Rev	Change	Date	Prep.	Rev.	Appr.

General tolerances for linear and angular dimensions according to ISO 1302.
9A04-431

General tolerances for linear and angular dimensions and geometrical tolerances according to ISO 1302.
9A04-431